


- ① MAXIMUM ADJUSTMENT ALLOWED BETWEEN THE TOP CONE SECTION AND BOTTOM CASTING IS 12". A MAXIMUM OF 3 INDIVIDUAL ADJUSTING RINGS SHALL BE USED. TALLER 6" OR 12" RINGS SHALL BE USED WHERE ADJUSTMENT REQUIRES MORE THAN 3 (2") RINGS.



AIR RELEASE MANHOLE/AIR AND VACUUM RELEASE

NOT TO SCALE

PLATE 5013

AIR RELEASE MANHOLE

STANDARD DETAIL
PLATE NO:
5013

APPROVED: ADOPTED BY CITY COUNCIL ON JANUARY 12, 2004

REVISED: REVISION ADOPTED BY CITY COUNCIL ON FEBRUARY 26, 2007

REMARKS:

SAINT PETER UTILITY STANDARD DETAIL

